

DICHIARAZIONE DI CONFORMITÀ

SmartDHOME Srl che le teste termostatiche TTD, nei modelli elencati di seguito, hanno un tempo di risposta inferiore ai 40 minuti e pertanto sono da considerarsi a **bassa inerzia termica**. L'analisi intrapresa riguarda i rischi inerenti all'uso del prodotto e/o in base alle misure effettuate.

SmartDHOME Srl dichiara di aver condotto tutte le prove come previsto dalla norma **UNI EN215**.

SmartDHOME Srl that the TTD thermostatic heads, in the models listed below, have a response time of less than 40 minutes and therefore are to be considered with low thermal inertia. The analysis undertaken concerns the risks inherent in the use of the product and/or on the basis of the measures taken.

*SmartDHOME Srl declares that it has conducted all the tests as required by the **UNI EN215** standard.*

Descrizione	SmartDHOME PN
TESTINA TERMOSTATICA DIGITALE TTD300	01333-1150-00
TESTINA TERMOSTATICA DIGITALE TTD150	01333-0100-00
TESTINA TERMOSTATICA DIGITALE TTD101	01333-0004-00
TESTINA TERMOSTATICA DIGITALE TTD800	01333-1300-01

Zibido San Giacomo (Mi) – 17/11/2022

Smartdhome Srl

Product Manager

Marco Vicamini



SmartDHOME Srl.